

Pittsburgh County RWD & SWM District #20

44 Water Street

Carlton Landing, OK 74432

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER**

Our water system recently violated drinking water standards. Although this was not an emergency, as our customers, you have a right to know what happened, what you should do, and what we are doing to correct this situation.

**Pittsburg Co RWD #20 Has Levels of Total Trihalomethanes (TTHMs) Above Water Standards**

We routinely monitor for the presence of drinking water contaminants. Testing results we received for indicated time periods(s) show that our system exceeds the standard, or maximum contaminant level (MCL), for total trihalomethanes. The standard or MCL for total trihalomethanes is 0.080 mg/l. It is determined by averaging all the samples collected at each sampling location for the past 12 months. The level of total trihalomethanes averaged at our system’s locations was the following:

<u>Monitoring Location</u>	<u>Twelve-month time period</u>	<u>Locational RAA</u>
TTHM – Hydrant at Lot #11 Ridgeline Road	Fourth Quarter 2025	0.092 mg/l
TTHM – Hydrant at Lot #11 Ridgeline Road	Third Quarter 2025	0.086 mg/l
TTHM – Hydrant at Lot #11 Ridgeline Road	First Quarter 2025	0.085 mg/l
TTHM – Hydrant at Lot #11 Ridgeline Road	Fourth Quarter 2024	0.093 mg/l

**What should I do?** There is nothing you need to do unless you have a severely compromised immune system, have an infant or are elderly. These people may be at an increased risk and should seek advice about drinking water from their health care providers.

**What does this mean?** This is not an emergency. If it had been, you would have been notified immediately. Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have increased risk of getting cancer.

**CORRECTIVE ACTION**

**What happened?** We purchase water Longtown Rural Water District #1 (Pittsburg Co RWD #1) and they exceeded limits during the testing period.

**What is being done?** We and Longtown RWD #1 are increasing our flushing of the system(s).

**When will the violation be resolved?** Steps have already been taken to resolve or address this issue.

For further information contact: Greg Buckley at 918-707-5005

Please share this information will all other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by Pittsburgh CO RWD #20

PWSID#: OK3006139

Case Number: CO 24-193

Date Distributed: 2-17-2026